

STANDARD INFORMATION

Standard: UL 231

Standard ID: Power Outlets [UL 231:2016 Ed.10+R:22Aug2024]

Previous Standard ID: Power Outlets [UL 231:2016 Ed.10+R:12Oct2022]

EFFECTIVE DATE OF NEW/REVISED REQUIREMENTS

Effective Date: **August 22, 2026**

IMPACT, OVERVIEW, AND ACTION REQUIRED

Impact Statement: Per our accreditation, Intertek is required to review reports against the standard revisions to confirm compliance. Once compliance is confirmed, the standard reference in the report is updated to show continued compliance to the technical requirements of the standard. Reports not updated to this version by the effective date above will be withdrawn.

Overview of Changes: Revised requirements for Weather Resistant Receptacles in Power Outlets. Specific details of new/revisted requirements are found in table below.

Current Listings Not Active? – Please immediately identify any current Listing Reports or products that are no longer active and should be removed from our records. We will do this at no charge as long as Intertek is notified in writing prior to the review of your reports.



STANDARD INFORMATION

CLAUSE	VERDICT	COMMENT
		<i>Additions to existing requirements are <u>underlined</u> and deletions are shown lined-out below.</i>
8	Info	Wiring Devices
8.2	Info	Receptacles
8.2.11		All 15- and 20-ampere, 125- and 250-volt nonlocking receptacles, including receptacles with integral Class A ground-fault circuit protection for personnel, <u>of the following configurations</u> shall be rated as "weather-resistant" type in accordance with the Standard for Attachment Plugs and Receptacles, UL 498. a) <u>5-15R, 6-15R, and 6-20R (15- and 20-ampere, 125 and 250 volt);</u> b) <u>6-30R, TT-30R, 14-30R (30-ampere, 125 and 250 volt); and</u> c) <u>14-50R (50-ampere, 125/250 volt)</u>